



PUBLIC WORKS DEPARTMENT

CITY OF PORTSMOUTH

680 Peverly Hill Road

Portsmouth N.H. 03801

(603) 427-1530 FAX (603) 427-1539

February 8, 2011

Stephanie Larson

NHDES

PO Box 95 - 29 Hazen Drive

Concord, NH 03301

Subject: Daily Maximum Fecal Violations

NPDES Permit No. NH0090000

Discharge No. 005A

Dear Ms. Larson:

This is the five-day follow up letter for three daily maximum fecal violations for the Pease Facility. The following conditions occurred:

Date of Sample: 2/4/11

Chlorine Residual before Dechlorination at the time of Sample: 7.2 mg/L

Free Chlorine 0.6 mg/L

Plant Flow at time of Sample: 0.86 MGD

Fecal Results: 23/100ml

Date of Sample: 2/5/11

Chlorine Residual before Dechlorination at the time of Sample: 8.2 mg/L

Free Chlorine 0.8 mg/L

Plant Flow at time of Sample: 0.72 MGD

Fecal Results: 30/100ml

Date of Sample: 2/6/11

Chlorine Residual before Dechlorination at the time of Sample: 10.5 mg/L

Free Chlorine 0.0 mg/L

Plant Flow at time of Sample: .72MGD

Fecal Results: 23/100ml

Please call if you have any questions or need additional information.

Sincerely,

Paula Anania

Cc: Joy Hilton, USEPA

Peter Rice